



# Santhome Enviro services

**NABL (ISO / IEC 17025:2005) Accredited &  
(A CONSTITUENT BOARD OF QUALITY COUNCIL OF INDIA)  
ISO 9001:2015 Certified Laboratory**

L4/2, East Avenue Road, (Near SBI) Korattur, Chennai-600 080



Ph : 044 - 42181525 / Mob: 9791530069

Email ID: santhomeenviro@gmail.com | Website : www.santhomeenvirolab.in



Cert No.TC-7144



TEST REPORT					
Sample Ref No. : SAS/W/273/10			Report No. : 064/10		
Customer Name : M/s. Affordable Water Solutions, Auroville			Report Date : 24.10.2020		
Address : Aurobrindavan, Main building, Auroville, T.N. India. 605101.			Page: 1 of 1		
Sample Description : Water			Received On : 20.10.2020		
Sample Drawn By/ Date : Santhome Lab/20.10.2020			Commenced On : 20.10.2020		
Customer's Reference : Letter Dated on 20.10.2020			Completed On : 24.10.2020		
Sample Mark : Water treated with sachet " Emergency Water Purifier"					
Sl. No	Parameters	Raw water	Water treated with sachet "Emergency Water Purifier"	Requirement (Acceptable Limit) as per IS 10500:2012	PROTOCOL:
1	Iron ( mg/l)	4.80	0.10	1	IS 3025 (Part 53)
<b>End of Report</b> for <b>SANTHOME ENVIRO SERVICES</b>					
			 Verified & Authorized By M.Maria Frank Omer - Quality Manager		
					

- NOTE: 1. Test results shown in this test report relate only to the items tested.  
2. This test report shall not be reproduce anywhere except in full and in same format without the Approval of the laboratory  
3. Unless informed by the customer the test items will not be retained for more than 10 days from the date of issue of test report (exceptional for Microbiology and wastewater for which retaining time 7 days.)