ABC Techno Labs
Quality Uncompromised

ABC Techno Labs India Private Limited®

ABC TOWER, #400, 13th Street, SIDCO Industrial Estate-North Phase, Ambattur, Chennai – 600 098
Phone: +91 44 2625 7788 / 99, +91 94442 60000 / 95661 87777
Email: lab@abctechnolab.com / Web: www.abctechnolab.com

TC - 5770

(An ISO : 9001, ISO : 14001, ISO : 45001 & ISO : 22000 Certified Company)

Accredited by NABL ISO/IEC 17025:2017, NABET / QCI, Approved by FSSAI
Recognised by MoEFCC, BIS, APEDA

TEST REPORT

ISSUED TO:

M/s. Affordable Water solutions Auroville.
Aurobrindhavan, Main Building Auroville,
Tamil Nadu - 605 101.

Customer Provided Details					
Sample Name	Water Samples		Customer Ref	Mail confirmation	
Seal if Any	Nil		Marks on Sample	Nil	
Lab Provided Details					
Report Number	ABCTLN/2020/10/2129-2130	Date of Receipt	21-10-2020	Analysis Commenced	21-10-2020
Analysis Completed	24-10-2020	Sample Condition	Good	Sample Qty.	500 ml
Report Date	24-10-2020	Sample Drawn by	Santhome Enviro Services	Date of Sampling	-
Location of Sampling	-	Sampling Method	-		

S.No	Sample Description	Test Parameter	Test Method	Unit	Results	Acceptable Limits as per IS 10500 - 2012
1	Raw Water	E.coli	APHA 23rd Edn –Chap.9222 B	cfu/ml	95000	-
2	Water Treated with Sachet Emergency Water Purifier.	E.coli	IS 15185 - 2016	NA	Absent/100ml	Absent/100ml

.....END OF REPORT.....

Verified by

M. Krishnamoorthy
Head - Microbiology

Authorised Signatory